



**ADDENDUM
INVITATION FOR BID
OVERHEAD DOOR MAINTENANCE, REPAIR, AND REPLACEMENT SERVICES
CITY OF AUSTIN, TEXAS**

IFB: JRD0031

Addendum No: 2

Date of Addendum: July 7, 2016

This addendum is to incorporate the following changes to the above-referenced solicitation.

1.0 Questions and Answers.

(Q1) Some of the doors listed are designated as Fire doors. Will these doors that require an annual drop test by NFPA 80 code be billed at Time and Material separate from the PM, since they require more labor to perform these special tests?

(A1) The fire doors on Attachment A – Overhead Door List under the Department of Aviation section have not been installed to perform as indicated under the National Fire Protection Association (NFPA) 80: Standard for Fire Doors and Other Opening Protectives regulations do not currently require an annual drop test.

The fire doors on Attachment A – Overhead Door List under the Austin Convention Center Department are true fire doors as indicated under NFPA 80 that should close when an alarm sounds. These doors shall meet the requirements of NFPA 80 and the Contractor should work together with the Fire Alarm Contractor to satisfy the requirements under NFPA 80.

The Contractor shall bill these drop tests based on the Hourly Rate and Discount off Price List for the materials used during the testing process as indicated on Section 0600 – Bid Sheet.

2.0 ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME.

BY THE SIGNATURES affixed below, this Addendum is hereby incorporated into and made a part of the above-referenced Invitation for Bid.

APPROVED BY:


Jonathan Dalchau, Senior Buyer Specialist
Purchasing Office

7/7/2016
Date

ACKNOWLEDGED BY:

Vendor Name

Authorized Signature

Date

***RETURN A COPY OF THIS ADDENDUM
to the Purchasing Office, City of Austin, Texas with your bid.
Failure to do so may constitute grounds for rejection of your bid.***